



NOTES:

1. ONE-HALF (1/2) INCH EXPANSION JOINTS FOR FULL DEPTH OF THE SIDEWALK (RUBBERIZED MATERIAL) 20 FT. O.C. MAX.
2. SLABS SHALL BE SCORED (TRAVERSE DUMMY JOINTS) EVERY FIVE (5) FEET O.C. APPROXIMATE 1/8" WIDE AND AT LEAST 1" DEEP.
3. ALL SIDEWALKS TO HAVE A 2% MAXIMUM CROSS SLOPE.
4. SIDEWALK DEPTH SHALL BE 6" AT ALL DRIVEWAY LOCATIONS.
5. SIDEWALK TO BE LIGHT BROOM FINISHED IN DIRECTION OF SIDEWALK WIDTH.
6. FORM OUTSIDE EDGES AND JOINTS WITH A 1/4-INCH RADIUS-EDGING TOOL.
7. CURB RAMPS AS REQUIRED AND WHERE INDICATED, CONSTRUCT CEMENT CONCRETE SIDEWALK FOR CURB RAMP CONFIGURATIONS AS INDICATED ON THE MOST CURRENT STANDARD DRAWINGS (RC-67M) AND ADA REQUIREMENTS, EXCEPT FOR THE DETECTABLE WARNING SURFACE (DWS) LOCATED AT THE BOTTOM OF EACH RAMP. CONSTRUCT THE DWS AS SPECIFIED IN SECTION 695 IN PUBLICATION 408.
8. DO NOT REMOVE SIDE FORMS UNTIL AT LEAST 12 HOURS AFTER PLACING CONCRETE. AFTER REMOVAL OF FORM, FILL MINOR HONEYCOMBED AREAS WITH MORTAR.
9. SIDEWALK SHALL BE A MINIMUM OF 4 FEET WIDE UNLESS EXISTING SIDEWALK IS WIDER, THEN SIDEWALK SHALL MATCH EXISTING SIDEWALK.
10. PROVIDE MATERIALS AND CONSTRUCTION MEETING THE REQUIREMENTS OF PENNDOT PUBLICATION 408. THIS INCLUDES MEETING AMBIENT TEMPERATURE REQUIREMENTS FOR CONCRETE PLACEMENT.

TYPICAL CONCRETE SIDEWALK DETAIL

NOT TO SCALE